

Water hardness by location

	Country of manufacturing				
Locality	Australia mg/L CaCO ₃	International mmol/L CaCO ₃	Germany °D	England °E	France °f
Bealiba	86	0.86	4.8	6.0	8.6
Bendigo (Axedale)	78	0.78	4.4	5.5	7.8
Bendigo (Northern)	82	0.82	4.6	5.7	8.2
Bendigo (Raywood)	77	0.77	4.3	5.4	7.7
Bendigo (Sebastian)	81	0.81	4.6	5.7	8.1
Bendigo (Southern)	82	0.82	4.6	5.7	8.2
Bendigo (Spring Gully)	81	0.81	4.6	5.7	8.1
Big Hill	79	0.79	4.4	5.5	7.9
Boort	108	1.08	6.1	7.5	10.8
Bridgewater	18	0.18	1.0	1.3	1.8
Castlemaine	62	0.62	3.5	4.3	6.2
Cohuna	22	0.22	1.2	1.5	2.2
Dunolly	49	0.49	2.8	3.4	4.9
Echuca	17	0.17	1.0	1.2	1.7
Elmore	111	1.11	6.2	7.8	11.1
Epsom - Huntly	80	0.80	4.5	5.6	8.0
Fryerstown	62	0.62	3.5	4.3	6.2
Goornong	101	1.01	5.7	7.1	10.1
Guildford	63	0.63	3.5	4.4	6.3
Gunbower	24	0.24	1.3	1.7	2.4
Harcourt	68	0.68	3.8	4.8	6.8

	Country of manufacturing				
Locality	Australia mg/L CaCO ₃	International mmol/L CaCO ₃	Germany °D	England °E	France °f
Heathcote	95	0.95	5.3	6.6	9.5
Inglewood	18	0.18	1.0	1.3	1.8
Junortoun	79	0.79	4.4	5.5	7.9
Korong Vale	14	0.14	0.8	1.0	1.4
Kyneton	61	0.61	3.4	4.3	6.1
Laanecoorie	48	0.48	2.7	3.4	4.8
Leitchville	23	0.23	1.3	1.6	2.3
Lockington	26	0.26	1.5	1.8	2.6
Maiden Gully - Marong	83	0.83	4.7	5.8	8.3
Maldon	69	0.69	3.9	4.8	6.9
Malmsbury	65	0.65	3.7	4.5	6.5
Newstead	63	0.63	3.5	4.4	6.3
Pyramid Hill	34	0.34	1.9	2.4	3.4
Rochester	22	0.22	1.2	1.5	2.2
Serpentine	35	0.35	2.0	2.4	3.5
Strathfieldsaye	81	0.81	4.6	5.7	8.1
Taradale - Elphinstone	66	0.66	3.7	4.6	6.6
Tarnagulla	55	0.55	3.1	3.8	5.5
Tooborac	86	0.86	4.8	6.0	8.6
Trentham	59	0.59	3.3	4.1	5.9
Tylden	65	0.65	3.7	4.5	6.5
Wedderburn	16	0.16	0.9	1.1	1.6